

CERTIFICATE OF COMPLIANCE

Certificate Number 20130823-E51855
Report Reference E51855-19741023
Issue Date 2013-AUGUST-23

Issued to: BENDER INC
420 EAGLEVIEW BLVD
EXTON PA 19341

This is to certify that representative samples of ISOLATED POWER SYSTEMS EQUIPMENT
Health care facilities, isolated power panelboards,
Cat. Nos. TC or TAC

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1047, Isolated Power Systems Equipment;
CAN/CSA-C22.1, Canadian Electrical Code, Part I

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130823-E51855
Report Reference E51855-19761116
Issue Date 2013-AUGUST-23

Issued to: BENDER INC
420 EAGLEVIEW BLVD
EXTON PA 19341

This is to certify that representative samples of ISOLATED POWER SYSTEMS EQUIPMENT
Accessory X-Ray Receptacles, Model XRM

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 1047, Isolated Power Systems Equipment;
CAN/CSA-C22.1, Canadian Electrical Code, Part I Safety Standard for Electrical Installations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130823-E51855
Report Reference E51855-19790119
Issue Date 2013-AUGUST-23

Issued to: BENDER INC
420 EAGLEVIEW BLVD
EXTON PA 19341

This is to certify that representative samples of ISOLATED POWER SYSTEMS EQUIPMENT
Isolated power panels, Cat. No. IP, with circuit controls

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1047, Isolated Power Systems Equipment;
CAN/CSA-C22.1, Canadian Electrical Code, Part I Safety Standard for Electrical Installations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130823-E51855
Report Reference E51855-19801125
Issue Date 2013-AUGUST-23

Issued to: BENDER INC
420 EAGLEVIEW BLVD
EXTON PA 19341

This is to certify that representative samples of ISOLATED POWER SYSTEMS EQUIPMENT
Isolated power panelboards, Cat. No. SFC (Surgical Facility Center) followed by additional letters and numbers.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1047, Isolated Power Systems Equipment;
CAN/CSA-C22.1, Canadian Electrical Code, Part I Safety Standard for Electrical Installations

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130823-E51855
Report Reference E51855-19810218
Issue Date 2013-AUGUST-23

Issued to: BENDER INC
420 EAGLEVIEW BLVD
EXTON PA 19341

**This is to certify that
representative samples of**

ISOLATED POWER SYSTEMS EQUIPMENT
Accessory, Remote Ground and Receptacle Modules,
GPM to indicate number of grounding jacks and
receptacles.
May be followed by figures or letters suffixes to indicate
model differences.

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1047, Isolated Power Systems Equipment;
CAN/CSA-C22.1, Canadian Electrical Code, Part I Safety
Standard for Electrical Installations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130823-E51855
Report Reference E51855-19980403
Issue Date 2013-AUGUST-23

Issued to: BENDER INC
420 EAGLEVIEW BLVD
EXTON PA 19341

**This is to certify that
representative samples of**

ISOLATED POWER SYSTEMS EQUIPMENT
Models IP, ID and IX followed by Alpha numeric suffixes
denoting product variations

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 1047, Isolated Power Systems Equipment;
CAN/CSA-C22.1, Canadian Electrical Code, Part I Safety
Standard for Electrical Installations

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

